

2019 Water Quality Report

The Rural Community Water District of Georgetown County

System # 2220001

We're pleased to provide you with this year's Water Quality Report. We want to keep you informed about the water and services we have delivered to you over the past year. Our goal is to provide to you a safe and dependable supply of drinking water. We are committed to ensuring the quality of your water.

Our water is produced from four wells in Georgetown County. A Source Water Assessment Plan has been prepared for our system. If you have any questions about this report or concerning your water utility, please contact Will Cook, Director at 843-546-9003. We want you, our neighbors and valued customers, to be informed about your water utility. I'm pleased to report that our drinking water is safe and meets federal and state requirements. This report shows our water quality and what it means. If you want to learn more, please attend any of our regularly scheduled meetings. They are held on the first Tuesday of each month at 5:30 p.m. at our office located at 2360 North Fraser Street, Georgetown, SC.

The Rural Community Water District of Georgetown County routinely monitors for constituents in your drinking water according to Federal and State laws. As water travels over the land or underground, it can pick up substances or contaminants such as microbes and chemicals. All drinking water, including bottled drinking water, may be reasonably expected to contain at least small amounts of some constituents. It's important to remember that the presence of these constituents does not necessarily pose a health risk.

The table below shows the results of our monitoring for the period of January 1st to December 31st, 2019. In this table you will find the following terms and abbreviations:

Action Level (AL) - the concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.

Parts per million (ppm) or Milligrams per liter (mg/l) - one part per million corresponds to one minute in two years or a single penny in \$10,000.

Parts per billion (ppb) or Micrograms per liter - one part per billion corresponds to one minute in 2,000 years, or a single penny in \$10,000,000.

Maximum Contaminant Level - The "Maximum Allowed" (MCL) is the highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology. MCL's are set at very stringent levels. To understand the possible health effects described for many regulated constituents, a person would have to drink 2 liters of water every day at the MCL level for a lifetime to have a one-in-a-million chance of having the described health effect.

Maximum Contaminant Level Goal - The "Goal"(MCLG) is the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Maximum Residual Disinfectant Level (MRDL) - The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG) - The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Non-Detects (ND) - laboratory analysis indicates that the constituent is not present.

Regulated Contaminants

| Disinfectants and Disinfection By-Products | Collection Date | Highest Level Detected | Range of Levels Detected | MCLG | MCL | Units | Violation (Y/N) | Likely Source of Contamination |
|--|-----------------|------------------------|--------------------------|-----------------------|---------|-------|-----------------|---|
| Total Trihalomethane (TTHM) | 2019 | 23.4 | 23.4 – 23.4 | No goal for the total | 80 | ppb | N | By-product of drinking water disinfection |
| Haloacetic Acids (HAA5) | 2019 | 6 | 6.01 – 6.01 | No goal for the total | 60 | ppb | N | By-product of drinking water disinfection |
| Chlorine | 2019 | RAA 1.17 | .91 – 1.37 | MRDL 4 | MRDLG 4 | ppm | N | Water additive used to control microbes |
| Nitrate | 2019 | 0.02 | 0.02-0.02 | 10 | 10 | ppm | N | Runoff from fertilizer use; Leaching from septic tanks, sewage. Erosion of natural deposits. |
| Fluoride | 2017 | .84 | .72 - .84 | 4 | 4 | ppm | N | Erosion of natural deposits; Water additive which promotes strong teeth; Discharge from fertilizer and aluminum factories |

LEAD AND COPPER TEST RESULTS

| Lead and Copper | Date Sampled | MCLG | Action Level (AL) | 90 th percentile | # Sites Over AL | Units | Violation (Y/N) | Likely Source of Contamination |
|-----------------|--------------|------|-------------------|-----------------------------|-----------------|-------|-----------------|--|
| Copper | 2017 | 1.3 | 1.3 | 0.15 | 0 | ppm | N | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |
| Lead | 2017 | 0 | 15 | 2.1 | 0 | ppb | N | Corrosion of household plumbing systems; erosion of natural deposits; leaching from wood preservatives |

UNREGULATED CONTAMINANTS

| NAME | REPORTED LEVEL | RANGE Low - High |
|-------------|----------------|---------------------|
| Sodium 2017 | 200 ppm | 190 - 200 |

All sources of drinking water are subject to potential contamination by substances that are naturally occurring, or man-made. These substances can be microbes, inorganic or organic chemicals and radioactive substances. All drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's Safe Drinking Water Hotline at 1-800-426-4791.

If you have special health needs

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/CDC guidelines on appropriate means to lessen the risk of infection by cryptosporidium and other microbiological contaminants are available from the Safe Drinking Water Hotline (800-426-479) if present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children.

Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Rural Community Water District of Georgetown County is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you are concerned about lead in your drinking water, you may wish to have your water tested. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>.